

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

COVER SHEET

Program: GLAST

Procedure Number: LAT-TD-05671

Procedure Title: TEM/TPS EMI Acceptance Test Proc.

Controlling Document Number: _____

Controlling Document Step Number: _____

Unit S/N: GLAT 1752

Descriptive Comment: _____

TEST READINESS REVIEW COMPLETED AND APPROVED BY THE FOLLOWING:

Test Director: [Signature] Date: 2-14/05
Quality Assurance: [Signature] Date: 2-14-05
Test Conductor: [Signature] Date: 2-14-05

POST TEST REVIEW COMPLETED AND APPROVED BY THE FOLLOWING:

Test Director: [Signature] Date: 2-14-05
Quality Assurance: [Signature] Date: 2-14-05
Test Conductor: [Signature] Date: 2-14-05

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: GLAT 1752	Date/Temperature: 2-11-05 23	
Title: 4.2 Test Equipment		Operator:	QA: <i>ATC</i>	
Para./ Step	Test Equipment Description, Manufacturer	Model/LAT Number	Serial/Rev. Number	*Cal./Val. Date
4.2.1 - 1	Record Model/LAT number, Serial/Revision number, Calibration due dates and Validation date for all equipment used in this procedure:			
	** Digital Multi Meter, Fluke/Meterman	87-III/38XR	GLAT1002	5/4/05
	VME Crate, Dawn VME Products	11-1011777-2119	GLAT0404	1-20-06
	Oscilloscope	TDS-2024	GLAT1003	6-21-05
	Spectrum Analyzer	4395A	NA	NA
	Audio Isolation Transformer	6020-1A	NA	NA
	Audio Amplifier	6550-1	NA	NA
	Large Scale Capacitor (#1)	6512-106R	NA	NA
	Large Scale Capacitor (#2)	6512-106R	NA	NA
	VME, TST-STP Trans card	LAT-DS-00999	GLAT0221	1-20-06
	VME SBC MVME2304 card, Motorola	PN MVME2304-0123	GLAT0311	↓
	VME LCB Mezzanine card	LAT-TD-00860	GLAT0126	↓
	Software for the local PC	TEMPROD V00-00-00	V01-00-04	NA
	DC Power supply #1, BK Precision	BK 1786 1697	S240500299	8-14-05
	DC Power supply #2, BK Precision	BK 1786 1647	S240500296	8-14-05
	28 Volt supply cable (#1)	LAT-DS-03246	NA	1-20-06
	28 Volt supply cable (#2)	LAT-DS-03246	NA	1-20-06
	PS Control cable	LAT-DS-04831	NA	NA
	TEM to GASU cable	LAT-DS-05541	GLAT1954	2-8-06
	Power cable VME to TPS	LAT-DS-05540	GLAT1955	2-8-06
	LCB Transition board cable	LAT-DS-03247	GLAT0233	1-20-06
	TEM Test Board Assembly	LAT-DS-04465	GLAT1707	↓
	TEM Test board cooling fan assembly	LAT-DS-03567	NA	↓
	CAT5 Ethernet cable	TRD855PL-50	NA	↓
	RS-232 Cable	TDC003-7 (RECO98M conn)	NA	↓
	Ground jumper, Banana, Pomona	B-12-0	NA	NA
	PS extension cable	LAT-DS-04629	NA	NA
	TEM/TPS Assembly	LAT-DS-01643	GLAT1752	NA

* This column is for recording the calibration due date for a given piece of equipment or the date that EGSE was validated.

** Do not substitute other DMM's CAUTION: Fluke 87-III and Fluke 87-V are not the same, Fluke 87-V is not allowed.

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: GLAT 1752	Date/Temperature: 2/11/05
Title: 4.2 Test Equipment		Operator:	QA: <i>ffc</i>
Para./ Step	Title	Print Name	Signature
4.1.3 - 1	Record names of all personnel that take part in the test/operation:		
		Jeffrey Ludvik	<i>[Signature]</i>
		Drew Weger	<i>[Signature]</i>
		Joe Collinson	<i>[Signature] ffc</i>

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: <i>GLAT 1752</i>	Date: <i>2/11/05</i>	
Title: 4.1.4 Pre Operation Verifications		Operator:	QA: <i>FTC</i>	
Para./ Step	Description	Limits	Unit	Data
4.1.4	Pre-Operation Verifications			
-1	Notify QAE.	OK	OK/NG	✓
-2	Test Readiness Review is done.	OK	OK/NG	✓
-3	Record the EUT equipment:			
	TEM/TPS Assembly Part number	NA	NA	<i>LAT-DS-01643</i>
	TEM/TPS Assembly Serial number	NA	NA	<i>GLAT 1752</i>
-4	EGSE power is OFF.	OFF	ON/OFF	✓
-5	Set DMM to autoranging for resistance.	OK	OK/NG	✓
-6	Measure DMM lead resistance.	<2.0	Ω	<i>0.5Ω</i>
-7	Measure EUT to ground.	<2.0	Ω	<i>0.7Ω</i>
-8	Measure test equipment to ground.	<2.0	Ω	<i>0.5Ω</i>
-9	All connector savers are installed on the flight connections.	OK	OK/NG	✓
-10	The test equipment and participant lists have been completed.	OK	OK/NG	✓

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: <i>GLAT 1752</i>	Date: <i>2/11/05</i>		
Title: 4.3 CE102 Conducted Emissions, 10 kHz to 150 kHz		Operator:	QA: <i>ATC</i>		
Para./ Step	Description	Limits	Unit	Data	
4.3.1	Initial Test Set-Up and Calibration Check				
-2	Verify that the setup is complete.	OK	OK/NG	<i>✓</i>	
-6	Record data in the Table below:	OK	OK/NG	<i>OK</i>	
-7	Verify calibration data is good.	OK	OK/NG	<i>OK</i>	

Freq (MHz)	dBm out	Expected pk-pk voltage (V)	Measured pk-pk voltage (V)	Expected dBm on Analyzer	Actual dBm on Analyzer
10	1	0.71	<i>.688V</i>	-19.4	<i>-17.9403</i>
2	15	3.55	<i>3.60V</i>	-6.9	<i>-4.73</i>
.01	-13	0.141	<i>.152</i>	-70.3	<i>-70.600</i>

4.3.2	Conducted Emissions Test				
-2	Verify that the setup is complete.	OK	OK/NG	<i>OK</i>	
-7	Record data in the Table below:	OK	OK/NG	<i>OK</i>	
-10	Verify that all data is good for all six setups.	OK	OK/NG	<i>OK</i>	

Frequency Range (MHz)	Current Probe on	Setup to Recall	Pass/fail	Saved data filename
0.15 - 2	+28 V	CE102A	<i>✓</i>	A
2-6	+28 V	CE102B	<i>✓</i>	B
6-10	+28 V	CE102C	<i>✓</i>	C
0.15 - 2	+28 V return	CE102A	<i>✓</i>	A2
2-6	+28 V return	CE102B	<i>✓</i>	B2
6-10	+28 V return	CE102C	<i>✓</i>	C2

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: GLAT 1752	Date/Temperature: 2-11-05		
Title: CS 102 Conducted Susceptibility 10KHz to 150KHz		Operator:	QA: AFC		
Para./ Step	Description	Limits	Unit	Data	
4.4.1	Initial Test Set-up and Calibration Check				
-2	Verify setup	OK	OK/NG	OK	
-8	Verify all calibration data is good	OK	OK/NG	OK	
	Save analyzer data to floppy and record file name	D1.TXT			

TEST DATA SHEET		Unit S/N: GLAT 1752	Date/Temperature: 2-11-05		
Title: CS 102 Conducted Susceptibility 10KHz to 150KHz		Operator:	QA:		
Para./ Step	Description	Limits	Unit	Data	
4.4.2	Conducted Emissions Basic Test				
-2	Verify setup	OK	OK/NG	OK	
-6	Initial to show the sweep time was set	OK	OK/NG	OK	
-7	Verify that the test passed	OK	OK/NG	OK	
-10	Record TEM/TPS run number	OK	OK/NG		
-11	Record pass fail	OK	OK/NG	OK	
-12	Save analyzer data to floppy and record file name	D1.TXT			

AFC
2-14-05

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: <i>GLAT 1752</i>	Date/Temperature: <i>2/11/05</i>	
Title: CS 102 Conducted Susceptibility 10KHz to 150KHz		Operator:	QA: <i>ATC</i>	
Para./ Step	Description	Limits	Unit	Data
4.4.3	Conducted Susceptibility Noise Test			
-2	Record largest noise voltage CAL Bias (HV) (red connection)	<500 μ	Volts	<i>1064V</i>
-4	Record largest noise voltage CAL 3.3 analog (yellow connection)	<150 μ	Volts	<i>504V</i>
-6	Record largest noise voltage CAL 3.3 digital (green connection)	<200 μ	Volts	<i>304V</i>
-8	Record largest noise voltage TKR bias (HV) (blue connection)	<500 μ	Volts	<i>804V</i>
-10	Record largest noise voltage TKR 2.5 analog (green connection)	<150 μ	Volts	<i>504V</i>
-12	Record largest noise voltage TKR 1.5 analog (red connection)	<150 μ	Volts	<i>604V</i>
-14	Record largest noise voltage TKR 2.5 digital (yellow connection)	<150 μ	Volts	<i>504V</i>

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: GLAT 1752	Date/Temperature: 2/11/05		
Title: CS 102 Conducted Susceptibility 150KHz to 10MHz		Operator:	QA: AFC		
Para./ Step	Description	Limits	Unit	Data	
4.4.4	Initial Test Set-up and Calibration Check				
-2	Verify setup	OK	OK/NG	✓	
-6	Verify all calibration data is good	OK	OK/NG	✓	
-7	Record the changes and file name	E, J, X			

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N: GLAT 1752	Date/Temperature: 2/11/05		
Title: CS 102 Conducted Susceptibility 150Hz to 10MHz		Operator:	QA: <i>ATC</i>		
Para./ Step	Description	Limits	Unit	Data	
4.4.5	Conducted Emissions Register Test				
-2	Verify setup	OK	OK/NG	<i>OK</i>	
-6	Initial to show the sweep time was set	OK	OK/NG	<i>OK</i>	
-7	Verify that the data is within limits	OK	OK/NG	<i>OK</i>	
-10	Record TEM/TPS run number	OK	OK/NG		
-11	Record Pass/Fail	OK	OK/NG	<i>OK</i>	
-12	Save analyzer data and record file name	<i>E1.TXT</i>			

ATC
2-14-05

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

TEST DATA SHEET		Unit S/N:	Date/Temperature:		
Title: CS 102 Conducted Susceptibility 150Hz to 10MHz		GLAT1752	2/11/05		
		Operator:	QA: <i>ATC</i>		
Para./ Step	Description	Limits	Unit	Data	
4.4.6	Conducted Emissions Noise Test				
-2	Record largest noise voltage CAL Bias (HV) <i>RED</i>	<500 μ	Volts	90 μ V	
-4	Record largest noise voltage CAL 3.3 analog <i>YELLOW</i>	<150 μ	Volts	30 μ V	
-6	Record largest noise voltage CAL 3.3 digital <i>GREEN</i>	<200 μ	Volts	20 μ V	
-8	Record largest noise voltage TKR bias (HV) <i>BLUE</i>	<500 μ	Volts	80 μ V	
-10	Record largest noise voltage TKR 2.5 analog <i>GREEN</i>	<150 μ	Volts	30 μ V	
-12	Record largest noise voltage TKR 1.5 analog <i>RED</i>	<150 μ	Volts	30 μ V	
-14	Record largest noise voltage TKR 2.5 digital <i>YELLOW</i>	<150 μ	Volts	20 μ V	

Appendix G (Connector Mate/Demate Log)

GLAST LAT TEM/TPS EMI Acceptance Test Procedure

The Excel Mate/Demate log form that is below is the actual Excel file imported into this word document. You can copy and paste it into a folder and then open it as an Excel worksheet.

CONNECTOR MATE / DEMATE

UNIT DESCRIPTION:

Connector(s) Connector Reference Designator	Authorized by Procedure & para or NSR	Date M/D/Y	Mate or De-mate M or D	Flight or Test F or T	Verify Power Off Emp. ID#	Pre-mate Inspect		ESD Bleed and Connector Mate		Final Inspect	
						*Emp. ID#	QA	*Emp ID#	QA	*Emp. ID#	QA

Connector /Bracket R/D:

*Personnel that is Mate/Demate certified.

no mates/demates
connector saves
used
APC 2-1405